

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2014

CRAYS ROAD WATER ASSOC.  
Public Water Supply Name

007-0005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☒ Advertisement in local paper (attach copy of advertisement)  
☒ On water bills (attach copy of bill)  
☐ Email message (MUST Email the message to the address below)  
☐ Other \_\_\_\_\_

Date(s) customers were informed: 4/29/2015 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_\_ / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: \_\_\_\_\_ / /

- ☐ As a URL (Provide URL \_\_\_\_\_)  
☐ As an attachment  
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: CALHOUN CO JOURNAL

Date Published: 04/29/15

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_\_ / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

J. R. Acord, President  
Name/Title (President, Mayor, Owner, etc.)

5/13/15  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601) 576-7800

May be emailed to:  
[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

2014 Annual Drinking Water Quality Report  
Cross Roads Water Association  
PWS#: 0070005  
April 2015

2015 APR 27 AM 11:24

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Cross Roads Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Shane Cook at 662.983.8744. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings that are held on the second Tuesday of January at 7:00 PM at the Bentley Community Center.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| TEST RESULTS |               |                |                |  |                  |      |     |                                |
|--------------|---------------|----------------|----------------|--|------------------|------|-----|--------------------------------|
| Contaminant  | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |

| <b>Inorganic Contaminants</b>   |   |         |      |             |      |     |          |   |
|---------------------------------|---|---------|------|-------------|------|-----|----------|---|
| 8. Arsenic                      | N | 2013*   | 2.2  | .9 – 2.2    | ppb  | n/a | 10       | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes                    |
| 10. Barium                      | N | 2013*   | .164 | No Range    | ppm  | 2   | 2        | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium                    | N | 2013*   | 4.5  | No Range    | ppb  | 100 | 100      | Discharge from steel and pulp mills; erosion of natural deposits  |
| 16. Fluoride                    | N | 2013*   | .234 | .211 - .234 | ppm  | 4   | 4        | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead                        | N | 2012/14 | 1    | 0           | ppb  | 0   | AL=15    | Corrosion of household plumbing systems, erosion of natural deposits  |
| 20. Nitrite (as Nitrogen)       | N | 2014    | 1    | No Range    | ppm  | 1   | 1        | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits                               |
| 21. Selenium                    | N | 2013*   | 6.9  | No Range    | ppb  | 50  | 50       | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines                          |
| <b>Disinfection By-Products</b> |   |         |      |             |      |     |          |   |
| Chlorine                        | N | 2014    | .60  | .2 – 4      | mg/l | 0   | MRDL = 4 | Water additive used to control microbes   |

\* Most recent sample. No sample required for 2014.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Cross Roads Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## Proof Of Publication

STATE OF MISSISSIPPI,  
COUNTY OF CALHOUN

Personally came before me, the undersigned, a Notary Public, in and for Calhoun County, Mississippi, Joel McNeece, Publisher of The Calhoun County Journal, a newspaper published in Bruce, Calhoun County, in said state, who being duly sworn, deposes and says that The Calhoun County Journal is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858 of the Mississippi Code of 1942, and the publication of a notice, of which annexed copy, in the matter of

## CROSS ROADS DRINKING WATER QUALITY REPORT

has been made in said newspaper one time, to-wit:

On the 29 day of APR 2015

*Joel McNeece*

Joel McNeece  
Publisher

Sworn to and subscribed before me, this 29 day of APRIL, 2015.

*Lisa Denley McNeece*

Lisa Denley McNeece,  
Notary Public



# Cross Roads Water Assn. Drinking Water Quality Report

2014 Annual Drinking Water Quality Report  
Cross Roads Water Association  
PWS# 0076005  
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Cross Roads Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Shane Cook at 662.983.8744. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings that are held on the second Tuesday of January at 7:00 PM at the Bontley Community Center.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential use; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas production and refining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| TEST RESULTS                  |               |                |                |  |              |      |                                |
|-------------------------------|---------------|----------------|----------------|--|--------------|------|--------------------------------|
| Contaminant                   | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/MCL | Unit Measure | MCLG | Likely Source of Contamination |
| <b>Inorganic Contaminants</b> |               |                |                |  |              |      |                                |

|                           |   |         |     |           |     |     |       |   |
|---------------------------|---|---------|-----|-----------|-----|-----|-------|---|
| 8. Arsenic                | N | 2013*   | 2.2 | 9 - 2.2   | ppb | n/a | 10    | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes                    |
| 10. Barium                | N | 2013*   | 164 | No Range  | ppm | 2   | 2     | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium              | N | 2013*   | 4.5 | No Range  | ppb | 100 | 100   | Discharge from steel and pulp mills; erosion of natural deposits  |
| 18. Fluoride              | N | 2013*   | 234 | 211 - 234 | ppm | 4   | 4     | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead                  | N | 2012/14 | 0   | 0         | ppb | 0   | ALP16 | Corrosion of household plumbing system; erosion of natural deposits   |
| 20. Nitrite (as Nitrogen) | N | 2014    | 1   | No Range  | ppm | 1   | 1     | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits                               |
| 21. Selenium              | N | 2013*   | 8.9 | No Range  | ppb | 50  | 50    | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines                          |

|                          |   |      |    |       |      |   |          |   |
|--------------------------|---|------|----|-------|------|---|----------|---|
| Disinfection By-Products |   |      |    |       |      |   |          |   |
| Chlorine                 | N | 2014 | 60 | 2 - 4 | mg/l | 0 | MRDL = 4 | Water additive used to control microbes |

\* Most recent sample. No sample required for 2014.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, USDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Cross Roads Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

| ACCOUNT NO. | SERVICE FROM | SERVICE TO |
|-------------|--------------|------------|
| 01-2565000  | 01/01        | 01/27      |

| SERVICE ADDRESS  |
|------------------|
| 563 CR 380 CC MS |

| METER READINGS |          |      |
|----------------|----------|------|
| CURRENT        | PREVIOUS | USED |
| 1793500        | 1793500  |      |

| CHARGE FOR SERVICES |
|---------------------|
|                     |

|              |       |
|--------------|-------|
| PAST DUE     | 21.00 |
| NET DUE >>>  | 21.00 |
| SAVE THIS >> |       |
| GROSS DUE >> | 21.00 |

RETURN THIS STUB WITH PAYMENT TO:

**CROSSROADS WATER ASSN.**

P.O. BOX 1232  
CALHOUN CITY, MS 38916

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PAID  
PERMIT NO. 46  
CALHOUN CITY, MS 38916

PAY NET AMOUNT  
ON OR BEFORE  
DUE DATE

DUE DATE  
05/11/2015

PAY GROSS  
AMOUNT AFTER  
DUE DATE

NET AMOUNT  
21.00

SAVE THIS  
0.00

GROSS AMOUNT  
21.00

CCR REPORT IS AVAILABLE AT  
PAYMENT OFFICE IF REQUESTED

**RETURN SERVICE REQUESTED**

01-2565000  
ERIN BARNETT

563 CR 380  
CALHOUN CITY, MS 38916